

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 06-51-01858  
Name of Facility: Imagine Charter School At Broward  
Address: 9001 Westview Drive  
City, Zip: Coral Springs 33067

**Correct By: Next Inspection  
Re-Inspection Date: None**

Type: Charter School  
Owner: Imagine Schools  
Person In Charge: Javier Benitez Phone: 954-255-0020

**Inspection Information**

Purpose: Routine  
Inspection Date: 6/6/2016

Begin Time: 10:50 AM  
End Time: 11:29 AM

**Additional Information**

FEMALES ..... 468  
MALES ..... 407

CENSUS ..... 875

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	X 13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

**General Comments**

No General Comments Available

Email Address(es): milbrian@hotmail.com;sabrina.acevedo@imagineschools.com

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

<p>Violation #5. Maintenance &amp; Repair OBSERVED: CEILING TILES STAINED IN 4 GRADE CLASSROOM AND 2ND FLOOR SCIENCE ROOM</p> <p>OBSERVED: CELING TILES AND VENTS DUSTY IN ALL CLASSROOMS</p> <p>OBSERVED: LIGHT BULBS OUT IN ALL CLASSROOMS</p> <p>CODE REFERENCE: Maintenance &amp; Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.</p>
<p>Violation #13. Separation of Sexes OBSERVED: 3RD AND 4TH GRADE CLASSROOM WITH UNISEX RESTROOMS - DESIGNATE ONE RESTROOM FOR EACH SEX CODE REFERENCE: Separation of Sexes 64E-13.004(6)(a)(1.). Preschool grades through grade three shall be provided with toilet and handwashing facilities located within or adjoining classrooms and considered adequate without urinals. Common toilet facilities for both sexes shall not be allowed above the third grade.</p>

<p>Inspection Conducted By: Sharon Bures (45706) Work: (954) 467-4700 ex. 4235 Date: 6/6/2016</p>
---

Inspector Signature:

Handwritten signature of Sharon Bures.

Client Signature:

Handwritten signature of the client.