

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 06-51-01858
Name of Facility: Imagine Charter School At Broward
Address: 9001 Westview Drive
City, Zip: Coral Springs 33067

Correct By: Next Inspection
Re-Inspection Date: None

Type: Private Charter School
Owner: Imagine Schools
Person In Charge: Rebecca Chouinard Phone: 954-255-0020
PIC Email: rebecca.chouinard@imagineschools.org

Inspection Information

Purpose: Routine
Inspection Date: 4/23/2021

Begin Time: 11:34 AM
End Time: 12:52 PM

Additional Information

FEMALES 184
MALES 186

CENSUS 370

As per section 120.695, Florida Statutes (FS) this form will serve as a "Notice of Non-Compliance" for any violation noted. Items marked below violate one or more of the requirements of Chapter 6A-2.0040 Florida Administrative Code (FAC). Sanitation Standards in K-12 Private Schools and section 468. Florida Building Code (FBC), Schools, Colleges, and Universities. Violations must be corrected within the time period indicated in the results section above. Continued operation of this facility without making these corrections is a violation of section 6A-2.0040, FAC, and section 468 FBC. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT 13. Disinfectants	SAFETY
IN 1. School Site	IN 14. Handwash Facilities	IN 25. First Aid Kit
OUT 2. Playground	IN 15. Soap Dispensers	DIAPER CHANGING STATION
NA 3. Athletic Equipment	NA 16. Showers	NA 26. Location/Sanitizers
BUILDING	NA 17. Shower Water Temperature	NA 27. Changing Station & Mats
IN 4. Construction	WATER SUPPLY	NA 28. Handsink
OUT 5. Maintenance & Repair	IN 18. Approved Source	NA 29. Garbage Can
OUT 6. Lighting Standards	IN 19. Drinking Fountains	ANIMAL HEALTH AND SAFETY
IN 7. Heating, Ventilation, A/C	LIQUID WASTE	NA 30. Vaccination
IN 8. Natural Ventilation	IN 20. Sewage Disposal	NA 31. Animal Maintenance/Aggressive Animals
OUT 9. Mechanical Ventilation	IN 21. Solid Waste	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	PEST CONTROL	NA 32. Maintenance/Complaint
IN 10. Provided/Accessible	IN 22. Pest Control	NA 33. Other
IN 11. Toilet Floor Drains	IN 23. Brush /Trash	
IN 12. Toilet Facilities	IN 24. Water Collection/Drainage	

IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 3

General Comments

CLASSROOMS INSPECTED: 13, 20, 31, 32, 33, 35, 40, 44, 45, 54, ART, MEDIA CENTER, 57, 59, 73, 86, 322
TASK LEVEL LIGHTING: 20-41 FTC
FIRST AID KIT PROVIDED: YES
WATER FOUNTAINS OBSERVED: 7
PLAYGROUND CUSHION MATERIAL OBSERVED: RUBBER MAT

NOTE: OBSERVED KILN WAS UNPLUGGED IN ART ROOM S STORAGE ROOM. KILN HAS NOT BEEN IN USE FOR A FEW YEARS.

Email Address(es): rebecca.chouinard@imagineschools.org

Violations Comments

Violation #2. Playground

OBSERVE PLAYGROUND EQUIPMENT IN YELLOW PLAYGROUND WITH EXPOSED RUST ON SIDE OF STEPS. -CORRECTED ON SITE

CODE REFERENCE: Playgrounds and Athletic Equipment. 6A-2.0040(2)(a)(c). Playgrounds shall be constructed & maintained to permit maximum utilization of sites with elimination of sanitary & health hazards including mudholes, fragments of glass, stone & similar obstructions. 468.2.2. Playground & equipment shall be safe, structurally sound, vermin proof, & shall not have jagged or sharp projections. Playground equipment shall be anchored to suitable foundations. Mats, wood chips, or sand shall be used under climbing equipment, slides, & swings.

Violation #5. Maintenance & Repair

OBSERVED 1 DESK WITH SHARP EDGES IN CLASSROOM: 57. - CORRECTED ON SITE

OBSERVED CEILING TILES STAINED IN CLASSROOMS: 35, 45 & 54 AND IN BOYS' RESTROOM ON 2ND FLOOR.

CODE REFERENCE: Maintenance & Repair. 6A-2.0040(3)(b)(c). Buildings shall be kept clean & in good repair, free from hazardous conditions, such as loose or broken floor tiles & boards; loose moldings; loose hanging fixtures, pipes, electric wires; & broken plaster. Furnishings & equipment shall be kept clean & in good repair, free of missing parts & sharp edges.

Violation #6. Lighting Standards

OBSERVED SEVERAL LIGHTBULBS OUT INSIDE CLASSROOMS: 40, 322, IN YELLOW HALLWAY NEAR ROOM 27.

OBSERVED 20-39 FT CANDLES OF LIGHT AT TASK LEVEL IN ALL INSPECTED CLASSROOMS EXCEPT: 322, 57 & 59. MINIMUM 40FT CANDLES OF LIGHT IS REQUIRED.

CODE REFERENCE: Lighting Standards. 6A-2.0040(4)(a-b). All instructional spaces shall be capable of providing a minimum illumination of forty (40) foot-candles at normal task level. 468.3.2. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #9. Mechanical Ventilation

OBSERVED EXHAUSTS IS NOT WORKING IN STUDENT BATHROOMS IN CLASSROOMS: 33, 20 & 13.

CODE REFERENCE: Mechanical Ventilation. 6A-2.0040(5)(d)2.(a)(b). All occupied spaces which do not meet the requirements for natural ventilation shall be mechanically ventilated by means of electrically operated exhausts. The ventilation system shall maintain air movement throughout the room at the level of the seated students. Fans & blowers shall provide air movement without disturbing noise. 468.3.6.2. and 468.3.6.3. Kiln rooms & areas shall provide adequate exhaust to dispel emitted heat to the exterior, & they shall not be connected to any other exhaust system. 468.3.6.4. HVAC systems in chemistry labs & science classrooms shall be designed & installed to ensure that chemicals are not recirculated. 468.3.6.5. Rooms used for the storage, handling, and disposal of chemicals used in school, college, & university labs shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Violation #13. Disinfectants

OBSERVED AIR DEODORIZERS USED IN BOYS' TOILET ROOMS.

CODE REFERENCE: Disinfectants. 6A-2.0040(6)(a)3. Deodorizers shall not be used in toilet rooms. Air deodorizers are not to be confused with disinfectants.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Amythest Rawls (54900)
Inspector Contact Number: Work: (954) 412-7319 ex.
Print Client Name:
Date: 4/23/2021

Inspector Signature:

A circular stamp containing the initials "AR" in a stylized font.

Client Signature:

A handwritten signature in black ink, appearing to be "M. ...".